### IAN BENNIE AND ASSOCIATES

TEST REPORT NO. 2014-045-S4.1 to 4.8

### HANITA '5 MIL MATTE' FILM ON 4 MM FLOAT GLASS IMPACT TEST to AS/NZS 2208 - 1996

for

**Hanita Pacific** 

December 2014



Accredited Laboratory No. 2371 Accredited for compliance with ISO/IEC 17025.



# IAN BENNIE & ASSOCIATES PTY. LTD.

## **Building Performance Testing**

ACN: 007 133 253



### **TEST REPORT NUMBER 2014-045-S4.1 to 4.8**

**Test Client:** Hanita Pacific

**Sample I.D:** Material: Hanita '5 mil Matte' film on 4 mm float glass (film applied by

Hanita)

Size: 1900 mm x 860 mm (default size) Number of identical samples supplied: 8

**Test Method:** In accordance with Appendix D Impact Test of AS/NZS2208-1996, Safety

Glazing Materials in Buildings, amended 1999, the eight samples were tested for compliance with the requirements for Grade A Safety Glazing Materials. As the sample was asymmetrical, four samples were impacted on the film side

(Samples 2.1 to 2.4) and four on the glass side (Samples 2.5 to 2.8).

Conditioning: All samples were stored in a temperature control test room for more than 24

hours with an ambient temperature of  $22 \pm 3^{\circ}$  C prior to testing. All tests

were conducted in the same room with the temperature maintained.

**Result:** Observations are given in Table 1.

**Conclusion:** The Hanita '5 mil Matte' film on 4 mm float glass passed the impact test

requirements for Grade A Safety Glazing Materials.

**Test Location:** Ian Bennie & Associates Test Centre

**Test Date(s):** 21 November 2014

**Test Officer:** Ian Bennie

IBA Report: 2014-045-S4.1 to 4.8 - Page 1 of 2

**Table 1. Test Observations** 

Sample	Drop height when breakage occurred (mm)	Observations	Result
S4.1 FS	300	Numerous cracks were created in the glass but no openings occurred. No significant pieces released from the sample with only fine splinters of glass falling off.	Pass
S4.2 FS	300	Numerous cracks were created in the glass but no openings occurred. No significant pieces released from the sample with only fine splinters of glass falling off.	Pass
S4.3 FS	300	Numerous cracks were created in the glass but no openings occurred. No significant pieces released from the sample with only fine splinters of glass falling off.	Pass
S4.4 FS	300	Numerous cracks were created in the glass but no openings occurred. No significant pieces released from the sample with only fine splinters of glass falling off.	Pass
S4.5 GS	300	Numerous cracks were created in the glass but no openings occurred. No significant pieces released from the sample with only fine splinters of glass falling off.	Pass
S4.6 GS	300	Numerous cracks were created in the glass but no openings occurred. No significant pieces released from the sample with only fine splinters of glass falling off.	Pass
S4.7 GS	300	Numerous cracks were created in the glass but no openings occurred. No significant pieces released from the sample with only fine splinters of glass falling off.	Pass
S4.8 GS	300	Numerous cracks were created in the glass but no openings occurred. No significant pieces released from the sample with only 2 small fragments and fine splinters of glass falling off.	Pass

FS = film side impact

GS = glass side impact

## This report shall not be reproduced except in full.

#### **DISTRIBUTION:**



Ian Bennie, 1 December 2014 Authorised NATA Signatory

IBA Report: 2014-045-S4.1 to 4.8 - Page 2 of 2